



AENOR

Asociación Española de
Normalización y Certificación

CERTIFICADO AENOR DE PRODUCTO N° 012 / 001118
AENOR PRODUCT CERTIFICATE N°



La Asociación Española de Normalización y Certificación (AENOR) certifica que el producto
The Spanish Association for Standardisation and Certification (AENOR) certifies that the product

EXTINTOR PORTÁTIL

PORTABLE FIRE EXTINGUISHERS

Marca Trade Mark	Modelo Model	Carga Capacity	Eficacia Fire Rating
ZENITH	ZPP-12	9 kg POLVO ABC	34A 233B C

suministrado por

supplied by

GENERAL IBERICA DE EXTINTORES, S.A.
CR DE MAZARRON, Km. 2,100 30120 EL PALMAR (Murcia - ESPAÑA)

y elaborado en

and manufactured in

CR DE MAZARRON, KM. 2,100
30120 EL PALMAR (Murcia - ESPAÑA)

es conforme con

complies with

- UNE 23110-1:1996 (EN 3-1:1996)
- UNE 23110-2:1996 (EN 3-2:1996)
- UNE 23110-3:1994 (EN 3-3:1994)
- UNE 23110-4:1996 (EN 3-4:1996)
- UNE 23110-5:1996 (EN 3-5:1996)
- UNE 23110-5:1997 ERRATUM (EN 3-5/AC:1997)
- UNE 23110-6:1996 (EN 3-6:1995)
- UNE 23110-6/1M:2000 (EN 3-6/A1:1999)

Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 12.02.

In order to grant this Certificate, AENOR has tested the product and has verified the quality system used in its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with the stipulations of the Specific Rules RP 12.02.

Fecha de concesión: **2000-02-21**
First issued on:

Fecha de renovación: **2005-02-21**
Renewed on:

Fecha de caducidad: **2010-02-21**
Expires on:



No está autorizada la reproducción parcial de este documento.

The partial reproduction of this document is not permitted.